



Thorpe Hall, Thorpe Road, Howden, East Yorkshire DN14 7LS
Telephone 01430 430880
Registered in England No 7065076

CERTIFICATE OF TEST

Temporary edge protection system comprising of two Rapid Posts and a Rapid Panel

Test complies with the requirements of BS EN 13374:2004
Class A Temporary edge protection systems

Test height 3.4 Metres
Distance between posts 2.3 Metres
Date of test 02-06-2010
Test location: Rapid EPS test facility Oldham

Test load 60 Kgf
Deflection at test load 36mm

For and on behalf of Rapid EPS Ltd

Peter G. Hewson

A handwritten signature in black ink that reads "P. G. Hewson".

Managing Director
Rapid EPS Ltd